

令和5年7月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	雨	23.0	15.7	3.7	7.51							
2	晴	28.2	15.2	1.1	7.64							
3	晴	28.0	16.0	0.9	7.64							
4	曇	27.2	16.0	1.2	7.85							
5	曇	25.0	15.1	1.0	7.62	42.0	46.5	120	6.8	0.08	<0.02	
6	晴	27.7	15.9	1.0	7.65							
7	晴	30.0	15.5	0.6	7.64							
8	曇	26.6	16.0	1.5	7.60							
9	晴	26.2	15.8	0.6	7.65							
10	晴	26.3	15.8	0.7	7.60							
11	曇	29.5	15.8	0.6	7.65							
12	曇	28.6	16.0	1.5	7.71							
13	雨	23.3	15.9	0.9	7.64							
14	曇	26.3	15.5	0.5	7.62							
15	曇	27.0	15.5	0.9	7.60							
16	曇	28.0	15.6	1.9	7.58							
17	晴	32.0	17.0	1.0	7.60							
18	晴	30.8	16.0	0.8	7.60							
19	晴	31.0	16.0	0.6	7.66							
20	晴	32.2	16.0	1.7	7.57	42.1	41.4	117	7.9	0.07	<0.02	
21	晴	29.0	16.1	0.9	7.60							
22	晴	29.7	15.9	1.1	7.62							
23	晴	30.0	16.0	0.6	7.60							
24	晴	30.5	15.8	1.5	7.61							
25	晴	30.0	16.0	1.2	7.62							
26	晴											断水作業の為記録なし
27	晴											断水作業の為記録なし
28	晴	30.6	17.0	1.0	7.72							
29	晴	29.5	17.0	1.0	7.66							
30	晴	31.0	16.3	0.7	7.61							
31	晴	33.0	16.5	0.6	7.70							
平均		28.6	16.0	1.1	7.63	42.1	44.0	119	7.4	0.08	<0.02	
最高		33.0	17.0	3.7	7.85	42.1	46.5	120	7.9	0.08	<0.02	
最低		23.0	15.1	0.5	7.51	42.0	41.4	117	6.8	0.07	<0.02	