

令和7年8月分

ふじさん工業用水道 (富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 ℃	水 質 試 験 結 果 (滝戸沈砂池 : 原水)									備 考
			水 温 ℃	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	33.5	16.0	1.1	7.62							
2	晴	34.8	16.8	0.7	7.76							
3	晴	34.0	17.0	0.8	7.71							
4	晴	32.2	17.1	2.7	7.67	40.4	40.3	120	3.5	0.12	<0.02	
5	晴	33.0	17.0	0.9	7.61							
6	晴	34.0	16.5	1.1	7.68							
7	晴	30.0	17.2	1.2	7.60							
8	晴	31.9	16.5	0.8	7.55							
9	晴	31.5	16.5	0.8	7.85							
10	雨	25.0	16.0	3.8	7.64							
11	雨	25.5	17.0	1.8	7.75							
12	晴	28.0	17.4	0.9	7.69							
13	曇	30.5	17.0	1.1	7.74							
14	晴	29.0	16.4	1.1	7.74							
15	晴	31.0	16.6	0.5	7.68							
16	曇	26.4	16.5	1.0	7.71							
17	晴	30.5	16.8	0.6	7.78							
18	晴	31.0	16.1	0.7	7.74	42.7	43.0	165	7.3	<0.02	<0.02	
19	晴	30.5	16.2	0.8	7.77							
20	晴	30.1	16.9	0.7	7.67							
21	晴	32.5	16.2	0.9	7.78							
22	晴	32.0	17.1	0.8	7.68							
23	晴	31.8	16.8	0.6	7.81							
24	晴	30.5	17.0	0.8	7.80							
25	晴	31.5	16.5	0.8	7.75							
26	晴	30.0	17.0	1.0	7.55							
27	晴	31.0	16.5	1.3	7.58							
28	晴	31.0	16.5	0.8	7.60							
29	晴	30.0	16.5	0.9	7.77							
30	晴	33.0	16.7	0.9	7.74							
31	晴	34.2	16.9	0.7	7.71							
平均		31.0	16.7	1.1	7.70	41.6	41.7	143	5.4	0.07	<0.02	
最高		34.8	17.4	3.8	7.85	42.7	43.0	165	7.3	0.12	<0.02	
最低		25.0	16.0	0.5	7.55	40.4	40.3	120	3.5	<0.02	<0.02	