

令和7年9月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 ℃	水 質 試 験 結 果 (滝戸沈砂池 : 原水)									備 考
			水 温 ℃	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	31.0	16.5	0.8	7.64	43.3	44.2	150	8.1	<0.02	<0.02	
2	晴	33.5	16.9	0.8	7.70							
3	晴	32.0	17.0	1.0	7.74							
4	曇	29.0	16.8	1.1	7.74							
5	雨	25.0	18.5	10.9	7.75							
6	晴	30.0	17.2	5.1	7.85							
7	晴	30.5	16.8	1.5	7.90							
8	晴	31.2	16.5	1.5	7.81							
9	晴	32.0	17.0	1.4	7.68							
10	晴	32.0	16.8	1.0	7.72							
11	晴	31.5	17.0	1.0	7.92							
12	晴	28.0	17.6	13.8	7.84							
13	雨	23.8	17.1	3.5	7.83							
14	晴	32.0	17.0	1.0	7.95							
15	晴	28.3	16.3	1.3	7.82							
16	晴	31.0	17.0	0.6	7.82	41.1	42.6	125	6.2	0.04	<0.02	
17	晴	31.7	16.3	1.0	7.88							
18	曇	30.0	17.0	0.6	7.85							
19	晴	27.0	16.7	1.1	7.88							
20	雨	21.3	16.5	0.6	7.85							
21	晴	29.7	16.2	0.7	7.93							
22	晴	26.5	15.9	1.3	7.95							
23	晴	25.0	15.0	0.5	7.91							
24	晴	26.0	14.8	0.8	7.89							
25	晴	27.5	15.0	0.7	7.87							
26	晴	32.5	16.0	0.8	7.86							
27	曇	24.2	15.5	0.7	7.81							
28	晴	28.2	15.5	0.5	7.89							
29	曇	28.5	16.0	0.6	7.86							
30	曇	24.5	15.7	0.7	7.87							
31												
平均		28.8	16.5	1.9	7.83	42.2	43.4	138	7.2	0.03	<0.02	
最高		33.5	18.5	13.8	7.95	43.3	44.2	150	8.1	0.04	<0.02	
最低		21.3	14.8	0.5	7.64	41.1	42.6	125	6.2	<0.02	<0.02	