

令和8年3月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	19.0	16.0	0.6	7.77							
2	曇	16.8	13.0	0.5	7.70	43.1	46.7	131	11.5	<0.02	<0.02	
3	雨	8.0	13.0	2.7	7.52							
4	晴	15.0	11.8	1.5	7.85							
5	晴	15.7	11.0	0.7	7.82							
6	晴	15.0	11.7	0.4	7.84							
7	晴	17.5	15.0	0.8	7.77							
8	晴	13.4	11.8	0.7	7.80							
9	晴	9.7	11.3	0.7	7.68							
10	晴	11.5	11.0	0.6	7.91							
11	晴	7.5	11.5	0.4	7.91							
12	晴	12.3	11.5	0.4	7.90							
13	晴	7.0	11.9	0.4	7.60							
14	晴	15.0	11.5	0.5	7.86							
15	晴	15.0	11.5	0.6	7.91							
16	晴	12.2	12.1	1.0	7.81	40.2	43.6	124	11.1	0.04	<0.02	
17	晴	14.2	12.3	0.6	7.85							
18	晴	16.0	12.0	0.4	7.84							
19	雨	13.0	13.0	0.7	7.79							
20	晴	15.5	13.0	0.7	7.91							
21	晴	15.0	12.0	0.6	7.93							
22	晴	16.0	11.7	0.8	7.93							
23	曇	10.7	12.2	0.7	7.81							
24	晴	17.0	12.3	0.5	7.83							
25	雨	11.5	12.5	0.6	7.82							
26	雨	14.1	12.3	0.9	7.84							
27	晴	17.0	12.4	0.7	7.89							
28	晴	18.0	13.0	0.5	7.94							
29	晴	20.5	13.0	0.4	8.02							
30	曇	14.8	13.2	0.5	7.87							
31	雨	14.5	13.5	1.2	7.81							
平均		14.1	12.4	0.7	7.83	41.7	45.2	128	11.3	0.03	<0.02	
最高		20.5	16.0	2.7	8.02	43.1	46.7	131	11.5	0.04	<0.02	
最低		7.0	11.0	0.4	7.52	40.2	43.6	124	11.1	<0.02	<0.02	