

令和8年4月

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池:原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	17.5	14.0	1.7	7.90							
2	雨	12.8	12.5	6.8	7.48							
3	晴	17.0	11.7	2.0	7.48							
4	雨	14.0	12.5	0.8	7.47							
5	曇	18.3	13.5	2.4	7.56							
6	晴	19.7	13.2	0.7	7.53	38.0	40.6	109	8.0	0.03	<0.02	
7	曇	17.0	13.5	0.8	7.35							
8	晴	18.0	11.5	1.0	7.47							
9	晴	18.0	12.2	0.7	7.48							
10	雨	15.0	13.5	2.6	7.34							
11	晴	26.0	14.0	1.7	7.57							
12	晴	21.0	13.3	0.9	7.55							
13	晴	22.0	13.0	0.8	7.53							
14	晴	23.5	13.5	0.9	7.49							
15	曇	19.0	13.7	0.9	7.47							
16	晴	23.0	14.4	0.6	7.50							
17	晴	16.0	13.5	0.8	7.56							
18	晴	22.0	13.5	0.7	7.63							
19	晴	23.5	13.5	0.7	7.63							
20	晴	22.0	14.0	1.0	7.58	41.2	42.5	118	10.3	<0.02	<0.02	
21	曇	17.0	14.0	0.4	7.24							
22	晴	20.0	14.2	0.8	7.58							
23	雨	17.0	13.8	0.6	7.35							
24	曇	16.5	13.5	1.1	7.48							
25	曇	17.8	13.8	0.6	7.59							
26	晴	21.4	21.0	0.6	7.73							
27	曇	17.0	14.0	3.6	7.48							
28	晴	21.0	14.8	0.8	7.62							
29	曇	19.0	14.0	0.7	7.57							
30	曇	15.0	14.0	1.0	7.30							
31												
平均		18.9	13.7	1.3	7.52	39.6	41.6	114	9.2	0.02	<0.02	
最高		26.0	21.0	6.8	7.90	41.2	42.5	118	10.3	0.03	<0.02	
最低		12.8	11.5	0.4	7.24	38.0	40.6	109	8.0	<0.02	<0.02	