

令和8年5月分

ふじさん工業用水道(富士川) 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (滝戸沈砂池 : 原水)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	雨	14.0	13.5	6.3	7.48							
2	晴	23.0	13.0	1.2	7.73							
3	晴	24.0	14.0	1.0	7.70							
4	曇	21.2	15.5	21.8	7.53							
5	晴	23.8	13.5	1.5	7.82							
6	曇	18.0	13.0	1.1	7.68							
7	晴	25.0	14.0	0.4	7.67							
8	曇	22.5	14.5	1.0	7.73							
9	晴	21.0	14.0	0.8	7.87							
10	晴	23.6	14.0	0.7	7.86							
11	曇	21.0	14.0	0.8	7.64	40.6	40.6	125	9.2	0.06	<0.02	
12	晴	22.0	14.0	0.8	7.73							
13	晴	24.0	14.0	0.4	7.62							
14	晴	26.0	13.8	0.3	7.70							
15	晴	23.0	14.0	0.9	7.76							
16	晴	24.8	14.5	0.5	7.81							
17	晴	28.0	14.8	0.5	7.90							
18	晴	24.5	14.0	0.9	7.86	41.4	42.4	121	9.9	0.02	<0.02	
19	晴	25.0	14.2	0.8	7.70							
20	晴	25.0	15.0	0.8	7.95							
21	雨	21.0	15.6	6.9	7.52							
22	曇	19.0	15.0	2.9	7.62							
23	曇	17.8	14.2	0.8	7.71							
24	曇	22.0	14.5	0.5	7.93							
25	晴	24.0	14.2	0.6	7.74							
26	晴	25.0	15.0	0.7	7.89							
27	晴	25.0	15.0	0.7	7.83							
28	曇	25.0	15.4	0.5	7.92							
29	曇	25.0	15.5	0.5	7.93							
30	晴	27.5	15.5	0.6	8.01							
31	晴	27.0	15.5	0.5	8.04							
平均		23.2	14.4	1.9	7.77	41.0	41.5	123	9.6	0.04	<0.02	
最高		28.0	15.6	21.8	8.04	41.4	42.4	125	9.9	0.06	<0.02	
最低		14.0	13.0	0.3	7.48	40.6	40.6	121	9.2	0.02	<0.02	