

令和 2年 4月分

静清工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (配水 : 配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	雨	15.1	9.6	0.46	7.6							
2	晴	11.0	9.7	0.52	7.3							
3	晴	13.0	9.7	0.50	7.5							
4	晴	14.0	9.7	0.50	7.3							
5	晴	17.0	9.8	0.40	7.5							
6	晴	14.0	9.8	0.41	7.3							
7	晴	14.0	9.8	0.42	7.6							
8	晴	15.0	9.8	0.42	7.4	53.0	81.0	126	1.4	<0.01	<0.02	
9	晴	16.5	9.8	0.30	7.4							
10	晴	13.2	9.8	0.30	7.4							
11	晴	14.1	9.9	0.30	7.5							
12	晴	14.0	9.9	0.23	7.3							
13	雨	10.3	9.7	0.22	7.5							
14	晴	14.8	9.6	0.23	7.3							
15	晴	16.0	9.6	0.24	7.4							
16	晴	16.8	9.7	0.23	7.3							
17	晴	13.4	9.7	0.24	7.3							
18	雨	12.8	9.0	0.26	7.3							
19	晴	16.0	9.6	0.25	7.3							
20	雨	11.1	9.6	0.20	7.3							
21	晴	18.0	9.4	0.21	7.4	53.0	76.0	96	1.3	<0.01	<0.02	
22	晴	18.5	9.5	0.21	7.6							
23	晴	13.8	9.5	0.23	7.3							
24	晴	14.5	9.6	0.20	7.3							
25	晴	14.5	9.6	0.21	7.3							
26	晴	19.7	9.8	0.17	7.6							
27	晴	18.5	9.8	0.19	7.5							
28	曇	16.3	9.8	0.18	7.3							
29	晴	16.5	9.8	0.18	7.6							
30	晴	20.0	9.9	0.19	7.4							
31												
平均		15.1	9.7	0.29	7.4	53.0	78.5	111	1.4	<0.01	<0.02	
最高		20.0	9.9	0.52	7.6	53.0	81.0	126	1.4	<0.01	<0.02	
最低		10.3	9.0	0.17	7.3	53.0	76.0	96	1.3	<0.01	<0.02	