

令和 2年 12月分

静清工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 °C	水質試験結果報告書 (配水 : 配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	10.5	17.8	0.10	7.3							
2	晴	12.4	17.7	0.08	7.4							
3	晴	11.0	17.7	0.15	7.3							
4	晴	12.6	17.6	0.13	7.6							
5	雨	9.7	17.6	0.06	7.2							
6	晴	9.5	17.5	0.05	7.5							
7	晴	9.1	17.5	0.00	7.3							
8	晴	11.4	17.4	0.02	7.4							
9	曇	12.1	17.4	0.10	7.3							
10	晴	11.0	17.3	0.10	7.2	54.0	81.0	143	1.2	<0.01	<0.02	
11	晴	12.8	17.3	0.04	7.2							
12	曇	10.5	17.3	0.02	7.2							
13	晴	10.0	17.2	0.00	7.6							
14	晴	13.0	17.2	0.04	7.6							
15	晴	7.8	17.1	0.00	7.2							
16	晴	4.9	17.0	0.00	7.2							
17	晴	3.8	16.9	0.02	7.6	55.0	77.0	117	1.2	<0.01	<0.02	
18	晴	3.8	16.8	0.05	7.2							
19	晴	8.9	16.8	0.05	7.6							
20	曇	2.5	16.7	0.00	7.4							
21	晴	3.2	16.6	0.06	7.5							
22	晴	4.0	16.6	0.01	7.3							
23	晴	4.8	16.5	0.00	7.4							
24	晴	6.4	16.5	0.00	7.2							
25	晴	9.8	16.5	0.00	7.5							
26	晴	5.5	16.5	0.04	7.2							
27	晴	6.0	16.4	0.01	7.5							
28	雨	8.0	16.4	0.00	7.2							
29	曇	9.0	16.4	0.02	7.3							
30	雨	11.0	16.3	0.00	7.7							
31	晴	2.5	16.2	0.02	7.5							
平均		8.3	17.0	0.04	7.4	54.5	79.0	130	1.2	<0.01	<0.02	
最高		13.0	17.8	0.15	7.7	55.0	81.0	143	1.2	<0.01	<0.02	
最低		2.5	16.2	0.00	7.2	54.0	77.0	117	1.2	<0.01	<0.02	