

令和3年6月分

静岡工業用水道 水質試験結果報告書（上原配水池）

採水時間 9:00

日	天候	気温 °C	水質試験結果（配水：配水池）									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	22.6	15.7	0.20	7.2							
2	曇	24.6	15.8	0.19	7.1	54.6	67.8	123	1.3	<0.01	<0.02	
3	曇	24.0	15.9	0.26	7.1							
4	雨	20.6	16.0	0.24	7.5							
5	晴	23.8	16.1	0.36	7.2							
6	曇	21.0	16.1	0.24	7.1							
7	曇	23.0	15.9	0.23	7.2							
8	晴	25.8	16.0	0.25	7.1							
9	晴	27.0	16.1	0.27	7.4							
10	晴	26.0	16.2	0.30	7.1							
11	晴	25.2	16.3	0.29	7.2							
12	曇	23.5	16.3	0.21	7.1							
13	曇	26.6	16.5	0.24	7.1							
14	雨	21.7	16.2	0.28	7.2							
15	晴	25.2	16.2	0.27	7.1							
16	曇	24.1	16.3	0.26	7.3	51.7	82.9	123	1.2	<0.01	<0.02	
17	晴	23.0	16.2	0.28	7.3							
18	曇	24.8	16.3	0.29	7.5							
19	雨	20.7	16.3	0.31	7.3							
20	晴	25.7	16.3	0.00	7.4							
21	晴	26.8	16.4	0.00	7.4							
22	曇	24.6	16.5	0.14	7.1							
23	曇	24.8	16.6	0.14	7.1							
24	晴	25.0	16.6	0.15	7.1							
25	曇	25.2	16.7	0.13	7.4							
26	晴	26.0	16.8	0.14	7.2							
27	曇	25.5	16.9	0.14	7.1							
28	晴	25.8	16.8	0.16	7.2							
29	晴	23.8	16.9	0.15	7.2							
30	雨	22.0	16.9	0.14	7.2							
平均		24.3	16.3	0.21	7.2	53.2	75.4	123	1.3	<0.01	<0.02	
最高		27.0	16.9	0.36	7.5	54.6	82.9	123	1.3	<0.01	<0.02	
最低		20.6	15.7	0.00	7.1	51.7	67.8	123	1.2	<0.01	<0.02	