

令和3年11月分

静岡工業用水道 水質試験結果報告書 (上原配水池)

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	17.5	18.9	0.42	7.2							
2	晴	19.0	18.8	0.43	7.2	53.0	75.5	135	1.2	<0.01	<0.02	
3	晴	18.2	18.9	0.41	7.2							
4	晴	16.8	18.8	0.48	7.5							
5	晴	16.8	18.8	0.46	7.2							
6	曇	16.8	18.7	0.45	7.2							
7	曇	15.5	18.7	0.40	7.3							
8	晴	18.4	18.6	0.46	7.4							
9	雨	17.8	18.6	0.44	7.3							
10	晴	16.8	18.6	0.52	7.2							
11	晴	16.2	18.5	0.48	7.3							
12	晴	16.8	18.5	0.50	7.3							
13	晴	12.4	18.4	0.53	7.6							
14	曇	14.0	18.3	0.43	7.2							
15	晴	11.8	18.3	0.46	7.2							
16	晴	13.5	18.2	0.48	7.2							
17	晴	15.0	18.2	0.47	7.5							
18	晴	14.5	18.2	0.48	7.4							
19	晴	13.0	18.1	0.47	7.3							
20	晴	13.6	18.1	0.50	7.6							
21	曇	15.0	18.0	0.35	7.4							
22	曇	16.8	18.0	0.36	7.2							
23	晴	12.5	18.0	0.40	7.3							
24	晴	11.6	17.8	0.40	7.2	56.7	81.6	118	1.2	<0.01	<0.02	
25	晴	11.2	17.7	0.40	7.2							
26	晴	12.8	17.7	0.39	7.3							
27	晴	10.8	17.6	0.40	7.3							
28	晴	6.9	17.6	0.32	7.5							
29	晴	9.0	17.5	0.31	7.6							
30	晴	10.6	17.4	0.30	7.2							
31												
平均		14.4	18.3	0.43	7.3	54.9	78.6	127	1.2	<0.01	<0.02	
最高		19.0	18.9	0.53	7.6	56.7	81.6	135	1.2	<0.01	<0.02	
最低		6.9	17.4	0.30	7.2	53.0	75.5	118	1.2	<0.01	<0.02	