

令和4年5月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	17.0	14.2	0.01	7.3							
2	晴	17.0	14.1	0.00	7.2							
3	晴	16.0	14.3	0.01	7.6							
4	晴	18.0	14.3	0.01	7.5							
5	晴	20.0	14.5	0.02	7.3							
6	晴	22.6	14.5	0.05	7.5							
7	晴	21.5	14.6	0.05	7.3							
8	晴	22.5	14.8	0.00	7.3							
9	曇	19.0	14.7	0.02	7.3							
10	晴	18.0	14.6	0.03	7.5	56.5	76.2	123	1.4	<0.01	<0.02	
11	晴	20.5	14.6	0.05	7.3							
12	曇	23.1	14.7	0.05	7.5							
13	雨	19.0	14.7	0.09	7.5							
14	曇	22.8	14.9	0.10	7.5							
15	晴	21.5	14.9	0.08	7.2							
16	雨	18.0	14.8	0.07	7.2							
17	曇	18.3	14.7	0.08	7.2							
18	晴	20.0	14.6	0.09	7.4	54.7	80.1	135	1.4	<0.01	<0.02	
19	晴	21.2	14.8	0.10	7.5							
20	曇	21.8	14.9	0.11	7.2							
21	雨	20.3	15.0	0.13	7.4							
22	晴	20.5	14.9	0.05	7.3							
23	晴	22.4	15.0	0.06	7.6							
24	曇	23.8	15.2	0.07	7.3							
25	晴	21.8	15.2	0.09	7.2							
26	曇	23.8	15.3	0.09	7.3							
27	雨	20.0	15.4	0.12	7.4							
28	晴	23.8	15.4	0.16	7.2							
29	晴	25.0	15.5	0.03	7.3							
30	晴	26.3	15.6	0.03	7.2							
31	雨	19.8	15.6	0.05	7.2							
平均		20.8	14.8	0.06	7.3	55.6	78.2	129	1.4	<0.01	<0.02	
最高		26.3	15.6	0.16	7.6	56.5	80.1	135	1.4	<0.01	<0.02	
最低		16.0	14.1	0.00	7.2	54.7	76.2	123	1.4	<0.01	<0.02	