

令和4年8月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	31.0	19.1	0.01	7.2							
2	晴	32.6	19.2	0.01	7.2							
3	晴	31.8	19.2	0.00	7.5	56.5	76.8	133	1.3	<0.01	<0.02	
4	曇	29.8	19.3	0.00	7.1							
5	晴	27.8	19.1	0.01	7.5							
6	雨	24.0	19.1	0.01	7.2							
7	晴	29.5	19.1	0.01	7.2							
8	晴	30.7	19.2	0.01	7.2							
9	晴	32.0	19.4	0.01	7.2							
10	晴	32.0	19.5	0.00	7.3							
11	晴	31.0	19.6	0.01	7.5							
12	曇	29.0	19.6	0.01	7.2							
13	雨	24.3	19.9	0.28	7.1							
14	曇	27.3	20.0	0.17	7.9							
15	晴	30.3	19.9	0.00	7.0							
16	晴	32.5	19.9	0.00	7.4							
17	曇	28.1	19.9	0.00	7.4	59.6	78.1	139	1.3	<0.01	<0.02	
18	雨	28.0	19.9	0.01	7.2							
19	晴	31.0	19.9	0.00	7.0							
20	晴	29.8	20.0	0.01	7.1							
21	曇	29.0	20.0	0.01	7.1							
22	晴	30.0	20.0	0.01	7.3							
23	曇	30.6	20.0	0.00	7.0							
24	晴	30.2	20.1	0.02	7.1							
25	曇	27.0	20.2	0.01	7.2							
26	曇	29.0	20.1	0.04	7.1							
27	晴	30.0	20.2	0.02	7.1							
28	曇	28.0	20.3	0.01	7.1							
29	晴	25.8	20.1	0.00	7.4							
30	晴	26.8	20.0	0.00	7.3							
31	雨	26.8	20.1	0.00	7.4							
平均		29.2	19.7	0.02	7.2	58.1	77.5	136	1.3	<0.01	<0.02	
最高		32.6	20.3	0.28	7.9	59.6	78.1	139	1.3	<0.01	<0.02	
最低		24.0	19.1	0.00	7.0	56.5	76.8	133	1.3	<0.01	<0.02	