

令和4年9月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	28.5	20.2	0.00	7.1							
2	曇	27.0	20.2	0.01	7.4							
3	晴	27.0	20.1	0.01	7.4							
4	晴	27.9	20.2	0.01	7.2							
5	晴	28.0	20.3	0.01	7.4							
6	曇	28.0	20.3	0.01	7.3							
7	雨	25.1	20.3	0.01	7.1	57.1	65.0	126	1.2	<0.01	<0.02	
8	雨	23.0	20.2	0.01	7.2							
9	曇	27.2	20.3	0.01	7.0							
10	晴	27.1	20.4	0.01	7.1							
11	晴	26.0	20.4	0.01	7.1							
12	晴	27.3	20.5	0.01	7.2							
13	晴	27.8	20.5	0.01	7.1							
14	晴	28.8	20.6	0.01	7.1							
15	曇	25.0	20.5	0.01	7.2							
16	晴	26.4	20.4	0.00	7.1							
17	曇	28.5	20.5	0.01	7.1							
18	雨	26.5	20.5	0.00	7.1							
19	曇	30.2	20.6	0.00	7.5							
20	曇	26.7	20.6	0.00	7.1	55.5	68.9	132	1.2	<0.01	<0.02	
21	曇	21.8	20.5	0.00	7.3							
22	曇	22.5	20.4	0.01	7.1							
23	曇	22.3	20.3	0.01	7.1							
24	雨	24.5	21.0	10.00	7.3							
25	雨	25.3	21.0	0.75	6.9							
26	晴	25.0	20.7	0.06	7.0							
27	晴	24.8	20.4	0.01	7.4							
28	晴	24.0	20.3	0.01	7.3							
29	曇	23.0	20.1	0.11	7.0							
30	晴	23.2	20.1	0.00	7.0							
31												
平均		25.9	20.4	0.37	7.2	56.3	67.0	129	1.2	<0.01	<0.02	
最高		30.2	21.0	10.00	7.5	57.1	68.9	132	1.2	<0.01	<0.02	
最低		21.8	20.1	0.00	6.9	55.5	65.0	126	1.2	<0.01	<0.02	