

令和4年10月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	23.5	20.1	0.00	7.1							
2	晴	24.0	20.1	0.00	7.1							
3	晴	24.0	20.3	0.01	7.1							
4	晴	25.0	20.3	0.00	7.2							
5	曇	27.0	20.3	0.01	7.1	54.0	65.2	134	1.4	<0.01	<0.02	
6	雨	16.7	20.1	0.00	7.1							
7	雨	14.8	19.9	0.01	7.1							
8	曇	19.5	19.8	0.01	7.3							
9	晴	19.5	19.8	0.00	7.2							
10	曇	19.3	19.8	0.01	7.5							
11	晴	21.2	19.8	0.00	7.2							
12	曇	20.8	19.8	0.01	7.5							
13	曇	19.0	19.8	0.01	7.1							
14	晴	21.3	19.8	0.00	7.1							
15	晴	23.0	19.9	0.01	7.5							
16	晴	22.7	20.0	0.01	7.1							
17	曇	25.3	20.0	0.00	7.5							
18	曇	21.0	19.9	0.00	7.3							
19	晴	17.0	19.7	0.00	7.5	54.6	69.3	119	1.3	<0.01	<0.02	
20	晴	17.8	19.7	0.00	7.1							
21	晴	17.2	19.7	0.01	7.1							
22	曇	20.0	19.6	0.00	7.6							
23	晴	19.2	19.6	0.00	7.2							
24	晴	18.6	19.6	0.00	7.1							
25	曇	14.9	19.4	0.00	7.3							
26	晴	14.7	19.2	0.14	7.2							
27	曇	15.2	19.2	0.11	7.1							
28	曇	16.3	19.1	0.06	7.3							
29	晴	17.0	19.1	0.00	7.5							
30	晴	16.0	19.1	0.01	7.5							
31	晴	16.8	19.0	0.01	7.2							
平均		19.6	19.7	0.01	7.3	54.3	67.3	127	1.4	<0.01	<0.02	
最高		27.0	20.3	0.14	7.6	54.6	69.3	134	1.4	<0.01	<0.02	
最低		14.7	19.0	0.00	7.1	54.0	65.2	119	1.3	<0.01	<0.02	