

令和4年12月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	15.2	18.0	0.00	7.2							
2	晴	11.1	17.9	0.00	7.1							
3	曇	11.7	17.9	0.05	7.2							
4	晴	10.0	17.8	0.05	7.2							
5	晴	13.4	17.8	0.10	7.5							
6	曇	12.1	17.8	0.09	7.2							
7	晴	9.6	17.7	0.07	7.5	56.7	76.1	136	1.3	<0.01	<0.02	
8	晴	8.0	17.6	0.04	7.2							
9	晴	9.3	17.6	0.04	7.2							
10	晴	10.0	17.5	0.05	7.5							
11	晴	10.5	17.5	0.03	7.2							
12	晴	10.8	17.5	0.07	7.2							
13	雨	10.0	17.5	0.03	7.2							
14	晴	11.8	17.4	0.02	7.2							
15	晴	5.5	17.3	0.01	7.2							
16	晴	6.9	17.2	0.02	7.6							
17	曇	9.0	17.2	0.01	7.2							
18	晴	7.0	17.2	0.01	7.2							
19	晴	3.8	17.0	0.00	7.4							
20	晴	3.8	16.9	0.01	7.2							
21	晴	6.6	16.9	0.00	7.4	54.0	75.8	128	1.3	分析装置故障のため鉄・マンガンデータなし		
22	雨	9.2	16.9	0.01	7.3							
23	晴	5.0	16.9	0.04	7.3							
24	晴	4.0	16.7	0.01	7.4							
25	晴	4.0	16.7	0.00	7.2							
26	晴	4.8	16.7	0.00	7.2							
27	晴	5.0	16.7	0.01	7.4							
28	晴	6.0	16.7	0.01	7.4							
29	晴	5.8	16.6	0.01	7.4							
30	晴	6.0	16.6	0.01	7.7							
31	晴	5.8	16.5	0.00	7.4							
平均		8.1	17.2	0.03	7.3	55.4	76.0	132	1.3	<0.01	<0.02	
最高		15.2	18.0	0.10	7.7	56.7	76.1	136	1.3	<0.01	<0.02	
最低		3.8	16.5	0.00	7.1	54.0	75.8	128	1.3	<0.01	<0.02	