

令和5年1月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	4.5	16.5	0.01	7.6							
2	晴	5.0	16.5	0.00	7.8							
3	晴	4.5	16.4	0.00	7.8							
4	晴	3.8	16.4	0.01	7.7							
5	晴	4.0	16.3	0.00	7.8							
6	晴	5.2	16.3	0.03	7.5							
7	晴	4.6	16.3	0.01	7.5							
8	晴	4.5	16.2	0.01	7.9							
9	晴	5.7	16.2	0.00	7.5							
10	晴	8.4	16.2	0.01	7.5							
11	晴	5.8	16.1	0.00	7.6	57.6	63	146	1.3	<0.03	<0.02	
12	晴	4.8	16.1	0.01	7.8							
13	晴	6.5	16.1	0.00	7.6							
14	雨	12.5	16.1	0.01	7.7							
15	曇	13.8	16.2	0.00	7.8							
16	曇	11.7	16.1	0.00	7.8							
17	曇	7.6	16.0	0.00	7.6							
18	曇	9.8	15.9	0.01	7.5							
19	晴	8.8	15.9	0.00	7.6							
20	晴	6.0	15.8	0.01	7.5							
21	晴	6.5	15.8	0.01	7.5							
22	曇	6.7	15.7	0.00	7.6							
23	雨	7.7	15.7	0.01	7.5							
24	曇	8.8	15.6	0.00	7.8	53.2	71	124	1.3	<0.03	<0.02	
25	晴	1.1	15.5	0.00	7.7							
26	晴	0.8	15.4	0.00	7.7							
27	晴	5.9	15.3	0.01	7.5							
28	晴	2.6	15.2	0.01	7.7							
29	晴	2.0	15.1	0.00	7.6							
30	晴	4.9	15.1	0.00	7.8							
31	晴	3.2	15.0	0.01	7.7							
平均		6.1	15.9	0.01	7.7	55.4	67	135	1.3	<0.03	<0.02	
最高		13.8	16.5	0.03	7.9	57.6	71	146	1.3	<0.03	<0.02	
最低		0.8	15.0	0.00	7.5	53.2	63	124	1.3	<0.03	<0.02	