

令和5年6月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	24.0	16.6	0.03	7.5							
2	雨	20.0	16.9	0.60	7.5							
3	曇	21.5	17.5	4.24	7.3							
4	晴	24.3	17.4	0.83	7.3							
5	曇	24.9	17.1	0.29	7.2							
6	曇	23.0	17.1	0.12	7.5	56.8	78.6	140	1.3	<0.01	<0.02	
7	晴	22.4	17.1	0.09	7.4							
8	晴	25.0	17.2	0.08	7.6							
9	雨	22.6	17.3	0.19	7.4							
10	晴	26.0	17.3	0.15	7.4							
11	雨	21.0	17.4	0.11	7.5							
12	雨	23.7	17.2	0.13	7.3							
13	晴	27.0	17.4	0.11	7.4							
14	雨	27.2	17.5	0.10	7.4							
15	曇	23.2	17.4	0.10	7.4							
16	晴	26.9	17.5	0.10	7.4							
17	晴	28.0	17.6	0.09	7.4							
18	晴	28.2	17.7	0.07	7.4							
19	晴	26.8	17.7	0.10	7.5							
20	曇	22.8	17.7	0.11	7.5							
21	晴	25.0	17.7	0.09	7.4	54.1	77.7	139	1.3	<0.01	<0.02	
22	曇	22.0	17.7	0.13	7.4							
23	曇	23.3	17.6	0.09	7.4							
24	晴	26.1	17.7	0.07	7.5							
25	曇	27.5	17.9	0.05	7.4							
26	曇	26.5	17.9	0.12	7.4							
27	曇	27.0	18.0	0.10	7.4							
28	晴	28.7	18.1	0.10	7.4							
29	晴	29.0	18.2	0.11	7.4							
30	曇	28.9	18.4	0.08	7.4							
31												
平均		25.1	17.5	0.29	7.4	55.5	78.2	140	1.3	<0.01	<0.02	
最高		29.0	18.4	4.24	7.6	56.8	78.6	140	1.3	<0.01	<0.02	
最低		20.0	16.6	0.03	7.2	54.1	77.7	139	1.3	<0.01	<0.02	