

令和6年12月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	9.4	18.5	0.00	7.5							
2	晴	10.0	18.4	0.00	7.7	54.6	74.3	113	1.4	<0.02	<0.02	
3	晴	11.3	18.3	0.00	7.5							
4	晴	12.4	18.3	0.01	7.4							
5	晴	11.5	18.3	0.00	7.3							
6	晴	11.3	18.1	0.01	7.4							
7	晴	10.2	18.0	0.00	7.4							
8	晴	9.5	17.9	0.00	7.4							
9	晴	7.4	17.8	0.00	7.7							
10	晴	8.0	17.7	0.00	7.5							
11	晴	8.3	17.7	0.00	7.5							
12	晴	9.2	17.5	0.01	7.4							
13	晴	6.5	17.4	0.00	7.6							
14	晴	8.5	17.4	0.00	7.7							
15	晴	6.0	17.3	0.00	7.5							
16	晴	8.1	17.2	0.00	7.7	53.9	71.5	115	1.5	<0.02	<0.02	
17	晴	6.3	17.1	0.00	7.4							
18	晴	8.6	17.1	0.00	7.5							
19	晴	8.5	17.1	0.00	7.3							
20	晴	5.8	16.9	0.00	7.5							
21	晴	7.6	16.9	0.00	7.5							
22	晴	8.2	16.9	0.00	7.4							
23	晴	3.8	16.8	0.00	7.3							
24	晴	5.1	16.7	0.00	7.5							
25	晴	6.0	16.6	0.00	7.5							
26	晴	8.9	16.6	0.00	7.4							
27	晴	8.9	16.6	0.00	7.4							
28	晴	6.2	16.5	0.00	7.5							
29	晴	4.2	16.4	0.00	7.5							
30	晴	6.0	16.4	0.00	7.6							
31	晴	7.0	16.3	0.00	7.5							
平均		8.0	17.3	0.00	7.5	54.3	72.9	114	1.5	<0.02	<0.02	
最高		12.4	18.5	0.01	7.7	54.6	74.3	115	1.5	<0.02	<0.02	
最低		3.8	16.3	0.00	7.3	53.9	71.5	113	1.4	<0.02	<0.02	