

令和7年2月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	7.5	14.9	0.00	7.5							
2	雨	6.2	14.8	0.00	7.6							
3	曇	8.2	14.8	0.00	7.4	54.4	73.7	111	1.5	<0.02	<0.02	
4	晴	7.5	14.8	0.00	7.5							
5	晴	3.1	14.6	0.00	7.6							
6	晴	2.0	14.5	0.00	7.5							
7	晴	4.2	14.5	0.00	7.4							
8	晴	2.5	14.5	0.00	7.4							
9	晴	2.5	14.5	0.00	7.6							
10	晴	4.2	14.4	0.00	7.4							
11	晴	4.9	14.4	0.00	7.5							
12	曇	7.9	14.4	0.00	7.4							
13	晴	12.5	14.5	0.00	7.6							
14	曇	8.3	14.5	0.00	7.5							
15	晴	8.3	14.5	0.00	7.6							
16	曇	10.4	14.5	0.00	7.5							
17	晴	9.8	14.5	0.00	7.5	53.8	75.6	119	1.5	<0.02	<0.02	
18	晴	5.0	14.4	0.00	7.8							
19	晴	5.3	14.3	0.00	7.6							
20	晴	4.6	14.2	0.00	7.7							
21	曇	2.2	14.2	0.00	7.5							
22	晴	5.8	14.2	0.00	7.4							
23	晴	4.0	14.1	0.00	7.8							
24	晴	6.0	14.1	0.00	7.4							
25	晴	5.5	14.0	0.00	7.9							
26	晴	12.0	14.1	0.00	7.6							
27	晴	8.0	14.1	0.00	7.8							
28	晴	11.0	14.1	0.00	7.6							
29												
30												
31												
平均		6.4	14.4	0.00	7.6	54.1	74.7	115	1.5	<0.02	<0.02	
最高		12.5	14.9	0.00	7.9	54.4	75.6	119	1.5	<0.02	<0.02	
最低		2.0	14.0	0.00	7.4	53.8	73.7	111	1.5	<0.02	<0.02	