

令和7年5月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水 質 試 験 結 果 （ 配水：配水池 ）									備 考
			水 温 °C	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	20.3	14.9	0.00	7.5							
2	雨	17.7	14.9	0.00	7.5							
3	晴	17.8	14.9	0.00	7.5							
4	曇	24.0	15.1	0.00	7.5							
5	雨	19.0	15.1	0.00	7.5							
6	晴	14.5	15.1	0.00	7.5							
7	晴	18.9	15.0	0.00	7.5	50.6	78.5	123	1.5	<0.02	<0.02	
8	曇	19.6	15.1	0.00	7.6							
9	曇	21.4	15.2	0.00	7.6							
10	雨	18.8	15.2	0.00	7.6							
11	曇	21.0	15.2	0.00	7.5							
12	曇	19.6	15.2	0.00	7.5							
13	晴	21.4	15.2	0.00	7.5							
14	曇	21.9	15.3	0.00	7.5							
15	晴	22.8	15.4	0.00	7.5							
16	晴	23.2	15.5	0.00	7.5							
17	雨	18.5	15.6	0.09	7.5							
18	晴	27.5	15.7	0.17	7.5							
19	曇	22.1	15.6	0.00	7.4	54.1	81.6	127	1.3	<0.02	<0.02	
20	晴	25.5	15.7	0.00	7.5							
21	曇	24.7	15.8	0.00	7.4							
22	曇	23.0	15.9	0.00	7.5							
23	曇	20.3	15.8	0.00	7.4							
24	曇	21.5	15.8	0.00	7.4							
25	曇	21.7	15.9	0.03	7.4							
26	曇	22.5	15.8	0.00	7.5							
27	曇	20.7	15.8	0.00	7.5							
28	晴	21.2	15.9	0.00	7.5							
29	曇	23.3	15.9	0.00	7.4							
30	曇	18.0	15.9	0.00	7.8							
31	曇	21.1	15.9	0.00	7.4							
平均		21.1	15.5	0.01	7.5	52.3	80.1	125	1.4	<0.02	<0.02	
最高		27.5	15.9	0.17	7.8	54.1	81.6	127	1.5	<0.02	<0.02	
最低		14.5	14.9	0.00	7.4	50.6	78.5	123	1.3	<0.02	<0.02	