

令和7年9月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 ℃	水 質 試 験 結 果 (配 水 : 配 水 池)									備 考
			水 温 ℃	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	30.8	21.1	0.05	7.4	54.3	77.9	152	1.1	<0.02	<0.02	
2	晴	32.0	21.1	0.00	7.4							
3	晴	30.8	21.1	0.00	7.4							
4	曇	29.0	21.0	0.00	7.4							
5	雨	26.0	21.0	0.00	7.4							
6	晴	27.7	21.2	0.15	7.2							
7	晴	27.5	21.1	0.00	7.4							
8	晴	29.0	21.2	0.00	7.6							
9	晴	30.8	21.3	0.00	7.3							
10	晴	30.8	21.4	0.00	7.4							
11	晴	29.1	21.5	0.00	7.4							
12	曇	27.7	21.4	0.00	7.6							
13	雨	24.5	21.4	0.00	7.5							
14	晴	30.0	21.6	0.00	7.4							
15	曇	30.0	21.5	0.00	7.4							
16	晴	29.8	21.5	0.00	7.4	57.7	82.0	143	1.2	<0.02	<0.02	
17	晴	29.1	21.5	0.00	7.3							
18	晴	30.4	21.6	0.00	7.3							
19	曇	25.1	21.4	0.00	7.2							
20	曇	23.9	21.4	0.00	7.2							
21	晴	27.5	21.3	0.00	7.2							
22	晴	25.2	21.3	0.00	7.4							
23	晴	24.0	21.2	0.00	7.4							
24	晴	23.5	21.2	0.00	7.4							
25	晴	25.0	21.2	0.00	7.4							
26	晴	26.0	21.2	0.00	7.3							
27	曇	26.6	21.3	0.00	7.3							
28	曇	27.0	21.2	0.00	7.3							
29	晴	28.6	21.2	0.00	7.3							
30	晴	25.8	21.1	0.00	7.4							
31												
平均		27.8	21.3	0.01	7.4	56.0	79.9	148	1.2	<0.02	<0.02	
最高		32.0	21.6	0.15	7.6	57.7	82.0	152	1.2	<0.02	<0.02	
最低		23.5	21.0	0.00	7.2	54.3	77.9	143	1.1	<0.02	<0.02	