

令和7年10月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 ℃	水 質 試 験 結 果 （ 配 水 : 配 水 池 ）									備 考
			水 温 ℃	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	23.5	21.0	0.01	7.4							
2	曇	23.0	20.7	0.00	7.4							
3	曇	25.0	20.7	0.03	7.3							
4	曇	24.3	20.7	0.00	7.4							
5	晴	25.0	20.6	0.05	7.4							
6	晴	26.2	20.7	0.00	7.3	57.2	77.3	124	1.1	<0.02	<0.02	
7	晴	24.2	20.7	0.00	7.4							
8	晴	24.9	20.7	0.00	7.3							
9	晴	26.6	20.7	0.00	7.3							
10	曇	22.0	20.6	0.00	7.3							
11	曇	22.0	20.6	0.00	7.2							
12	曇	21.0	20.5	0.00	7.7							
13	曇	21.0	20.4	0.00	7.5							
14	雨	19.5	20.4	0.00	7.3							
15	曇	20.0	20.3	0.00	7.3							
16	曇	21.0	20.3	0.11	7.3							
17	晴	23.8	20.3	0.00	7.3							
18	晴	22.2	20.3	0.00	7.5							
19	曇	23.0	20.3	0.00	7.2							
20	曇	20.9	20.3	0.00	7.2	54.7	79.3	130	1.2	<0.02	<0.02	
21	曇	17.3	20.2	0.00	7.3							
22	雨	15.6	20.0	0.00	7.4							
23	曇	15.9	19.9	0.00	7.4							
24	曇	16.6	19.9	0.00	7.4							
25	曇	15.5	19.8	0.00	7.4							
26	曇	18.3	19.8	0.00	7.3							
27	晴	20.5	19.8	0.00	7.5							
28	晴	16.6	19.8	0.00	7.4							
29	晴	17.0	19.8	0.00	7.4							
30	晴	16.9	19.7	0.03	7.4							
31	曇	18.0	19.7	0.00	7.3							
平均		20.9	20.3	0.01	7.4	55.9	78.3	127	1.2	<0.02	<0.02	
最高		26.6	21.0	0.11	7.7	57.2	79.3	130	1.2	<0.02	<0.02	
最低		15.5	19.7	0.00	7.2	54.7	77.3	124	1.1	<0.02	<0.02	