

令和7年11月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水 質 試 験 結 果 （ 配 水 : 配 水 池 ）									備 考
			水 温 °C	濁 度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	17.9	19.6	0.00	7.4							
2	曇	15.5	19.6	0.00	7.5							
3	晴	17.8	19.6	0.00	7.7							
4	晴	15.0	19.5	0.00	7.2	59.8	80.0	146	1.3	<0.02	<0.02	
5	曇	15.5	19.5	0.00	7.4							
6	晴	17.9	19.5	0.00	7.4							
7	晴	17.0	19.4	0.00	7.7							
8	曇	16.5	19.4	0.00	7.4							
9	曇	16.1	19.4	0.00	7.7							
10	晴	17.5	19.4	0.00	7.2							
11	晴	15.5	19.3	0.00	7.4							
12	曇	19.3	19.3	0.00	7.4							
13	曇	13.9	19.2	0.00	7.4							
14	晴	14.0	19.2	0.00	7.4							
15	晴	15.9	19.2	0.00	7.4							
16	晴	15.7	19.1	0.00	7.4							
17	晴	14.6	19.1	0.00	7.3	53.9	80.1	136	1.2	<0.02	<0.02	
18	晴	15.2	19.1	0.00	7.4							
19	晴	11.9	19.0	0.00	7.4							
20	晴	11.0	18.9	0.00	7.4							
21	晴	11.0	18.8	0.00	7.6							
22	晴	11.2	18.8	0.00	7.7							
23	晴	14.7	18.8	0.00	7.4							
24	晴	13.5	18.7	0.00	7.3							
25	曇	14.3	18.7	0.00	7.3							
26	晴	11.2	18.6	0.00	7.4							
27	曇	14.0	18.5	0.00	7.4							
28	晴	15.2	18.5	0.41	7.4							
29	曇	12.8	18.4	0.02	7.4							
30	晴	11.7	18.4	0.00	7.4							
31												
平均		14.8	19.1	0.01	7.4	56.9	80.1	141	1.3	<0.02	<0.02	
最高		19.3	19.6	0.41	7.7	59.8	80.1	146	1.3	<0.02	<0.02	
最低		11.0	18.4	0.00	7.2	53.9	80.0	136	1.2	<0.02	<0.02	