

令和8年2月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	4.5	15.3	0.00	7.5							
2	晴	5.0	15.3	0.00	7.6	53.2	82.3	125	1.2	<0.02	<0.02	
3	晴	4.8	15.3	0.00	7.4							
4	晴	5.8	15.3	0.00	7.4							
5	晴	6.5	15.2	0.00	7.5							
6	晴	8.0	15.2	0.00	7.4							
7	雨	7.8	15.2	0.00	7.5							
8	晴	3.5	15.0	0.00	7.5							
9	晴	1.6	14.9	0.00	7.3							
10	晴	5.7	14.9	0.00	7.4							
11	雨	8.8	14.9	0.00	7.4							
12	曇	7.3	14.4	0.22	7.5							
13	晴	8.1	14.7	0.33	7.5							
14	晴	8.1	14.7	0.24	7.5							
15	晴	10.6	14.8	0.20	7.5							
16	晴	12.0	14.8	0.50	7.5	56.1	82.4	135	1.3	<0.02	<0.02	
17	曇	7.0	14.8	0.20	7.5							
18	晴	6.9	14.7	0.18	7.5							
19	晴	6.8	14.7	0.16	7.5							
20	晴	8.5	14.6	0.16	7.5							
21	晴	9.0	14.7	0.12	7.5							
22	晴	8.2	14.7	0.00	7.5							
23	曇	17.2	14.8	0.00	7.5							
24	晴	14.0	14.9	0.01	7.5							
25	雨	18.5	14.8	0.11	7.5							
26	晴	14.0	14.8	0.01	7.5							
27	晴	13.1	14.8	0.00	7.5							
28	晴	15.0	14.9	0.00	7.5							
平均		8.8	14.9	0.09	7.5	54.6	82.3	130	1.3	<0.02	<0.02	
最高		18.5	15.3	0.50	7.6	56.1	82.4	135	1.3	<0.02	<0.02	
最低		1.6	14.4	0.00	7.3	53.2	82.3	125	1.2	<0.02	<0.02	