

令和8年3月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	14.0	14.9	0.00	7.5							
2	晴	15.7	15.0	0.00	7.5	56.9	84.5	126	1.4	<0.02	<0.02	
3	雨	10.8	14.8	0.04	7.5							
4	晴	13.2	14.7	0.00	7.5							
5	晴	10.9	14.7	0.00	7.5							
6	曇	12.0	14.7	0.00	7.5							
7	晴	14.0	14.8	0.00	7.5							
8	晴	10.0	14.7	0.00	7.5							
9	晴	10.0	14.6	0.00	7.5							
10	晴	10.4	14.5	0.00	7.5							
11	曇	7.0	14.5	0.00	7.5							
12	晴	9.8	14.5	0.00	7.5							
13	曇	9.0	14.4	0.00	7.5							
14	晴	10.9	14.4	0.00	7.5							
15	曇	11.1	14.5	0.00	7.5							
16	晴	12.1	14.5	0.00	7.5	52.1	85.5	129	1.3	<0.02	<0.02	
17	晴	12.5	14.6	0.00	7.5							
18	晴	13.6	14.6	0.00	7.5							
19	曇	14.0	14.7	0.05	7.5							
20	曇	14.8	14.7	0.00	7.5							
21	晴	12.7	14.7	0.01	7.5							
22	晴	12.3	14.7	0.00	7.5							
23	曇	13.0	14.6	0.11	7.5							
24	晴	14.4	14.6	0.00	7.5							
25	雨	13.5	14.6	0.05	7.5							
26	曇	13.8	14.5	0.00	7.5							
27	晴	14.7	14.6	0.00	7.5							
28	晴	15.4	14.7	0.00	7.5							
29	晴	16.2	14.8	0.00	7.5							
30	雨	16.0	14.8	0.00	7.5							
31	雨	15.8	14.8	0.02	7.5							
平均		12.7	14.7	0.01	7.5	54.5	85.0	128	1.4	<0.02	<0.02	
最高		16.2	15.0	0.11	7.5	56.9	85.5	129	1.4	<0.02	<0.02	
最低		7.0	14.4	0.00	7.5	52.1	84.5	126	1.3	<0.02	<0.02	