

令和8年4月

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 °C	水質試験結果 (配水:配水池)									備考
			水温 °C	濁度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	18.4	14.7	0.20	7.4							
2	曇	14.3	14.6	0.15	7.4							
3	晴	15.5	14.7	0.04	7.4							
4	曇	15.0	14.7	0.00	7.4							
5	曇	19.4	14.7	0.17	7.4							
6	晴	18.1	14.8	0.00	7.4	53.1	86.2	147	1.5	<0.02	<0.02	
7	曇	20.0	14.9	0.00	7.4							
8	晴	14.3	14.8	0.00	7.4							
9	晴	16.0	14.8	0.00	7.4							
10	雨	16.1	14.9	0.05	7.4							
11	晴	23.5	15.0	0.20	7.4							
12	晴	20.0	15.2	0.01	7.4							
13	晴	19.9	15.2	0.00	7.4							
14	晴	20.3	15.2	0.00	7.4							
15	曇	19.6	15.2	0.00	7.4							
16	晴	19.9	15.2	0.00	7.4							
17	晴	15.9	15.2	0.00	7.4							
18	曇	18.9	15.3	0.00	7.4							
19	曇	20.0	15.3	0.00	7.4							
20	晴	19.9	15.3	0.00	7.4	56.6	80.7	138	1.4	<0.02	<0.02	
21	曇	21.9	15.4	0.00	7.4							
22	晴	19.6	15.4	0.00	7.4							
23	雨	19.0	15.3	0.01	7.4							
24	曇	17.8	15.1	0.00	7.4							
25	曇	17.9	15.2	0.00	7.5							
26	晴	18.8	15.3	0.00	7.4							
27	曇	19.0	15.3	0.00	7.5							
28	晴	20.8	15.3	0.00	7.4							
29	曇	21.2	15.4	0.00	7.4							
30	曇	16.7	15.3	0.00	7.4							
31												
平均		18.6	15.1	0.03	7.4	54.9	83.4	143	1.5	<0.02	<0.02	
最高		23.5	15.4	0.20	7.5	56.6	86.2	147	1.5	<0.02	<0.02	
最低		14.3	14.6	0.00	7.4	53.1	80.7	138	1.4	<0.02	<0.02	