

令和8年7月分

静清工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 ℃	水 質 試 験 結 果 （ 配水：配水池 ）									備 考
			水 温 ℃	濁 度 度	p H	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	曇	26.2	17.6	0.00	7.3							
2	雨	21.7	17.7	0.06	7.3							
3	雨	22.9	17.7	0.00	7.3							
4	曇	25.5	17.7	0.00	7.3							
5	曇	24.7	17.7	0.00	7.3							
6	曇	23.3	17.6	0.00	7.3	56.7	80.3	127	1.3	<0.02	<0.02	
7	曇	24.0	17.5	0.00	7.3							
8	晴	26.0	17.7	0.00	7.3							
9	晴	26.2	17.8	0.00	7.3							
10	晴	28.0	18.0	0.00	7.3							
11	曇	27.9	18.2	0.00	7.3							
12	曇	27.9	18.2	0.00	7.4							
13	曇	26.6	18.2	0.00	7.3							
14	晴	29.7	18.1	0.00	7.3							
15	晴	30.0	18.4	0.00	7.3							
16	晴	30.0	18.6	0.00	7.3							
17	晴	32.0	18.6	0.00	7.3							
18	曇	30.3	18.7	0.00	7.4							
19	晴	29.2	18.8	0.00	7.3							
20	晴	31.0	18.8	0.00	7.3							
21	曇	31.8	19.0	0.00	7.3	54.6	75.5	129	1.3	<0.02	<0.02	
22	晴	31.9	19.1	0.00	7.3							
23	晴	31.8	19.1	0.00	7.3							
24	晴	32.5	19.2	0.00	7.3							
25	晴	32.2	19.3	0.00	7.3							
26	晴	31.0	19.3	0.00	7.3							
27	晴	29.1	19.2	0.00	7.3							
28	曇	28.3	19.1	0.01	7.3							
29	晴	27.4	19.0	0.00	7.3							
30	晴	29.8	19.2	0.00	7.3							
31	晴	31.2	19.2	0.00	7.3							
平均		28.4	18.5	0.00	7.3	55.7	77.9	128	1.3	<0.02	<0.02	
最高		32.5	19.3	0.06	7.4	56.7	80.3	129	1.3	<0.02	<0.02	
最低		21.7	17.5	0.00	7.3	54.6	75.5	127	1.3	<0.02	<0.02	