

令和8年8月分

静岡工業用水道 水質試験結果報告書

採水時間 9:00

日	天候	気温 ℃	水 質 試 験 結 果 （ 配水：配水池 ）									備 考
			水 温 ℃	濁 度 度	pH	アルカリ 度 mg/l	硬度 mg/l	蒸発 残留物 mg/l	塩化物 イオン mg/l	鉄 mg/l	マン ガン mg/l	
1	晴	30.5	19.4	0.00	7.3							
2	晴	32.0	19.5	0.00	7.3							
3	曇	29.4	19.5	0.07	7.2	55.1	77.6	121	1.3	<0.02	<0.02	
4	晴	28.0	19.3	0.04	7.2							
5	晴	27.9	19.4	0.04	7.2							
6	晴	29.2	19.5	0.03	7.2							
7	晴	30.1	19.6	0.04	7.3							
8	晴	30.0	19.7	0.06	7.2							
9	晴	30.0	19.7	0.04	7.2							
10	晴	28.5	19.7	0.04	7.3							
11	晴	28.0	19.7	0.06	7.3							
12	曇	24.8	19.5	0.03	7.2							
13	晴	29.0	19.5	0.02	7.2							
14	晴	29.0	19.6	0.03	7.2							
15	曇	26.9	19.6	0.04	7.2							
16	晴	27.8	19.6	0.04	7.2							
17	曇	29.0	19.5	0.04	7.2	56.2	79.1	125	1.3	<0.02	<0.02	
18	晴	28.9	19.6	0.02	7.2							
19	晴	28.9	19.6	0.05	7.2							
20	曇	28.2	19.7	0.05	7.2							
21	曇	28.5	19.6	0.04	7.2							
22	晴	29.6	19.7	0.04	7.2							
23	曇	29.1	19.8	0.08	7.2							
24	曇	28.5	19.8	0.06	7.2							
25	晴	30.1	19.8	0.05	7.2							
26	晴	31.1	20.0	0.04	7.2							
27	晴	31.8	20.0	0.04	7.2							
28	晴	28.4	20.0	0.04	7.2							
29	曇	29.8	19.9	0.04	7.2							
30	雨	24.5	19.8	0.03	7.2							
31	曇	27.0	19.7	0.02	7.2							
平均		28.9	19.7	0.04	7.2	55.7	78.4	123	1.3	<0.02	<0.02	
最高		32.0	20.0	0.08	7.3	56.2	79.1	125	1.3	<0.02	<0.02	
最低		24.5	19.3	0.00	7.2	55.1	77.6	121	1.3	<0.02	<0.02	